

Approval Number: 1506502  
Test Report: MAT/LAB 105J/a



Water Regulations Advisory Scheme Ltd.  
Unit 13,  
Willow Road,  
Pen y Fan Industrial Estate,  
Crumlin,  
Gwent,  
NP11 4EG

8<sup>th</sup> June 2015

Teadit Deutschland GmbH.  
Schanzenstrasse 35,  
51063 Koln,  
Germany

**WATER REGULATIONS ADVISORY SCHEME LTD. (WRAS)**  
**MATERIAL APPROVAL**

The material referred to in this letter is suitable for contact with wholesome water for domestic purposes having met the requirements of BS6920-1:2000 and/or 2014 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use.

**GLAND PACKINGS**

**5100**

Type 2007. Dark grey coloured, PTFE based, braided gland packing. For use with water up to 85°C. For use as a gland packing only having been tested at a reduced surface area to volume ratio.

**APPROVAL NUMBER: 1506502**  
**APPROVAL HOLDER: TEADIT DEUTSCHLAND GMBH.**

The Scheme reserves the right to review approval.  
Approval 1506502 is valid between June 2015 and June 2020

An entry, as above, will accordingly be included in the Water Fittings Directory on-line under the section headed, "Materials which have passed full tests of effect on water quality".

The Directory may be found at: [www.wras.co.uk/directory](http://www.wras.co.uk/directory)

Yours faithfully

A handwritten signature in black ink, appearing to read 'Jason Furnival', written in a cursive style.

Jason Furnival  
Approvals & Enquiries Manager  
Water Regulations Advisory Scheme